



BE PREPARED!

Temperatures are rising. Is your pool prepared for eager guests and fun-seeking children? Complete the mini-checklist below to see if your pool is ready:

Calaveras County
Environmental Health
Department
Recreational Health
Program 2016 Update

Do you have all your signs?

- No Lifeguard (if applicable)
- Occupant Capacity
- Artificial Respiration
- Emergency Number
- No Diving (if pool is less than 6' deep)
- Diarrhea Warning
- Spa Precautions/Emergency Shut-off
- Keep Closed

How is your pool maintained?

- New test reagents
- Chlorine is above 1.5 ppm
- pH is between 7.2 - 7.8
- Cyanuric acid is below 100 ppm
- All equipment is in good condition
- Daily log is completed daily
- Supplemental chemicals are on-site
- Skimmers are cleaned daily

Will your guests swim safely?

- Life ring/body hook/safety rope
- Anti-entrapment devices are installed
- Self-closing gate/approved fencing
- Spa shut-off works

How does your pool look?

- Clear; no debris or algae growth
- Water level at the mid-point of skimmers
- Recirculation equipment turned on during operating hours

CONGRATULATIONS!

If you completed this mini-checklist and were able to check off all the boxes, your pool/spa appears to be ready for your guests.

NEW THIS YEAR!

Pool/Spa Registrations will be mailed to facility operators once the annual fee has been received.

As a reminder: NO pool/spa inspections will be scheduled. Please have staff available to assist EHD inspectors upon arrival.



Expiring Drain Covers-

Drain covers have an average lifespan of five years and should be replaced in accordance with manufacturer's specifications, typically within three to seven years of installation. To ensure the safety of your pool, replace your drain cover before it expires. When changing your cover, your licensed pool contractor should submit a new certification letter to EHD.

Any questions regarding your pool/spa or this newsletter please contact EHD at (209) 754-6399 ext. 1