

## Public Pool & Spa Daily Maintenance Log

**California Code of Regulations, Title 22, section 65523:**

- a. The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant (e.g. chlorine) residual, pH, and maintenance procedures such as cleaning of filters and quantity of chemicals used.
- b. If cyanuric acid (stabilizer) is added to the pool, the concentration shall be measured a minimum of once per month and records shall be kept of the results.

Facility Name & Address: \_\_\_\_\_

Req. Flow Rate (gpm): \_\_\_\_\_ Month: \_\_\_\_\_ Year: \_\_\_\_\_

Day	Chlorine Residual (free chlorine)	pH	Chemicals Added (type & amount)	Other Maintenance (backwash, etc.)
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				

**Monthly Cyanuric Acid Test** – Date: \_\_\_\_\_ Results: \_\_\_\_\_

**Chlorine:** Minimum 1.5 ppm with cyanuric acid, 1.0 without cyanuric acid

**pH:** 7.2 – 8.0, Ideal 7.4 – 7.6

**Cyanuric Acid:** Should not exceed 100 ppm, Ideal 20 – 50 ppm

**Maximum Water Temperature:** 104 Degrees Fahrenheit

*Questions? Please contact the Calaveras County Environmental Health Department at (209) 754-6399.*