

Calaveras County Environmental Health Department
 891 Mountain Ranch Road
 San Andreas, CA 95249
 Phone: 209-754-6399 Fax: 209-754-6722

The following well setbacks shall be maintained pursuant to Chapter 8.20.270

Effective May 6, 2008

Minimum Distance From:	Feet:
Property line of parcels that are less than five (5) acres in area	10
Property line of parcels that are five (5) acres or more in area	50
Adjacent road easement where no specified right of way is identified	30*
On-site road easement where no specified right of way is identified	30**
Utility easement	10
Any sewer line (e.g. sanitary industrial main or lateral or combined storm water drain)	50
Subsurface sewage leach field or other sewage dispersal area	100
Watertight septic tank	100
Seepage pit or cesspool (the use of cesspools is prohibited)	150
Underground storage tank (petroleum products, e.g. gasoline & diesel)	150
Animal enclosures	100
Surface water (ponds, lakes, reservoirs, streams, brooks, flood plains & seasonal drainage)	25
Permanent structure	10
Active or inactive well on neighboring parcel	25
Animal water trough	25

* 30 feet from the center line of the road or the property line setback, whichever is greater.

** 30 feet from the center line of the road.